

Notified body No.1121  
Warrington Certification Limited, Holmesfield Road, Warrington, Cheshire, WA1 2DS, UK

## Certificate of Constancy of Performance

### 1121-CPR-KA5007

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

**Intended use:** Decorative Wall Covering

#### Product Performance

Harmonized Technical Specification - EN 15102:2007 + A1:2011			
Essential Characteristics	Performance	Method	Report Reference
Reaction to fire	B-s2, d0	EN 13501-1	WF 336672 Exova Warringtonfire
Release of formaldehyde	NPD	EN 12149:1997 (EN 12781:2001 or EN 13085:2001 for cork products)	Not Applicable
Heavy Metals	Pass	EN 12149:1997	1402-0198, RN-00701-14 Butterworth Laboratory's
Vinyl Monomer	Pass	EN 12149:1997	1402-0198, RN-00701-14 Butterworth Laboratory's
Sound Absorption	NPD	EN ISO 354 (testing) EN ISO 11654 (classification)	Not Applicable
Thermal resistance	NPD	EN 12667 EN 12524	Not Applicable

**Product Specification (See Page 3)**

**Certificate of constancy of performance**

**1121-CPR-KA5007**

Produced for

**LG Hausys**  
**16th Floor, One IFC, 10 Gookjegeumyoong-Ro**  
**Yeongdeungpo-Gu, Seoul, 150-876, Korea**

and produced in the manufacturing plant(s)

**AG/001**

**This is coded format and the information is held by the Notified Body.**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard

**EN 15102:2007/A1:2011**

under system 1 of AVCP are applied and that

***the product fulfils all the prescribed requirements set out above.***

This certificate was first issued on **03/04/14** and revised on **02/05/14** and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



Paul Duggan  
Certification Manager  
Warrington Certification Ltd



## Certificate of constancy of performance

**1121-CPR-KA5007**

### Product Specification

General description		A decorative wallcovering bonded to one face of a fibre cement board substrate
Product reference		"High Gloss"
Thickness of wallcovering		0.17mm(without release paper)
Weight per unit area of wallcovering		395g/m <sup>2</sup> (without release paper)
Colour reference		Any colour / pattern
Surface coating (test face)	Product reference	<b>See Note 1 below</b>
	Generic type	<b>See Note 1 below</b>
	Name of manufacturer	<b>See Note 1 below</b>
	Application rate	<b>See Note 1 below</b>
	Application method	Gravure printed
	Flame retardant details	<b>See Note 1 below</b>
PVC coating	Product reference	<b>See Note 1 below</b>
	Generic type	<b>See Note 1 below</b>
	Name of manufacturer	<b>See Note 1 below</b>
	Thickness	<b>See Note 1 below</b>
	Weight per unit area	<b>See Note 1 below</b>
	Application method	Calendaring
Adhesive	Product reference	<b>See Note 1 below</b>
	Generic type	<b>See Note 1 below</b>
	Name of manufacturer	<b>See Note 1 below</b>
	Application rate	<b>See Note 1 below</b>
	Application method	Comma coating
	Flame retardant details	<b>See Note 1 below</b>
Substrate	Trade name	"NT D4 604"
	Generic Description	Fibre cement board
	Supplier	Scheerders van de Kerkhove (SVK)
	Overall thickness	8mm
	Overall density	1800 ± 200 kg/m <sup>3</sup>
Flame retardant details		The substrate is inherently flame retardant
Brief description of manufacturing process of wallcovering		Calendaring process

**Note 1: The sponsor provided this information but at the specific request of the sponsor, this information has been omitted from the test report and is instead held on Warrington Certification Limited's confidential file relating to this investigation.**

----- End of Certificate -----